

CERTIFICATE

of constancy of performance

1922 - CPR - 0812

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fixed firefighting systems - Hose systems. Hose reels with semi-rigid hose

Hose diameter 25 mm

Reel diameter, maximum 585 mm

Drum diameter 220 mm

for installation in buildings, permanently connected to a water supply, for use by the occupants

placed on the market under the name or trade mark of **ACCO FIRE SOLUTIONS**

Metaform Tasarım Metal Yangın Ekipmanları Müh. San. ve Tic. Ltd. Şti.

OSTİM O.S.B. Mah. Ahievran Cad. 1227. Sok. No:6/E Yenimahalle ANKARA, TÜRKİYE

and produced in the manufacturing plant of

Metaform Tasarım Metal Yangın Ekipmanları Müh. San. ve Tic. Ltd. Şti.

OSTİM O.S.B. Mah. Ahlevran Cad. 1227. Sok. No:6/E Yenimahalle ANKARA, TÜRKİYE

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 671-1:2012

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 29.12.2016 and will remain valid until 29.12.2025 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Issued:
Burgas, 23 December 2024

Ref. No. 04-00

Manager:
dipl. eng. Anna Vasileva